

**POINTERS RUN ELEMENTARY SCHOOL
SYSTEMIC RENOVATION**

ADDENDUM NO. 4

DATE: April 17, 2019

ARCHITECT: Smolen, Emr, Ilkovitch Architects, Inc.
1355 Piccard Drive, Suite 200
Rockville, Maryland 20850
Phone: (301) 770-0177
Fax: (301) 330-3224

OWNER: Howard County Public School System

PROJECT: Pointers Run Elementary School Systemic Renovation
Clarksville, Maryland
Architect Project No. 17015

TO: All Prospective Bidders

The following changes are made a part of the Drawings and Specifications for the subject project, dated October 10, 2018. Receipt of this Addendum is to be acknowledged, in the space provided in the Bid Form. Failure to do so may subject the Bid to be considered as non-responsive.

A. REQUESTS FOR INFORMATION *See previous addenda for RFIs 1 through 35*

36. The fire alarm riser shows elevator modules and I can not find an elevator on the drawing?

RESPONSE: There is no elevator in the building. Disregard references to elevator modules.

37. The fire alarm riser shows fire pump modules and I can not locate a fire pump?

RESPONSE: The fire pump is located in Sprinkler Room 054 (Located on Sheet EF1.1).

38. The fire alarm riser shows dampers and I do not see any dampers on the electrical drawings and if there are then would also need to know the circuits?

RESPONSE: There are no fire dampers in the building. Disregard reference to smoke dampers.

B. CHANGES TO SPECIFICATIONS

None

C. CHANGES TO DRAWINGS

None

D. ATTACHMENTS

None

END OF ADDENDUM NO. 4