



ADDENDUM NO. 9C-4

May 19th, 2020

TO: ALL PLANHOLDERS

RE: Rebid of #13 High School New Construction (9C Wood Flooring Package)

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated April 30, 2020. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

Addendum No. 9C-4 consists of two (2) pages, including this cover letter.

19 May 20

Addendum No. 9C-4

Rebid of High School #13 New Construction 9C Wood Flooring

Howard County Public School System
Bid Number: 016.20.B4-1

The following is intended to clarify, correct, revise, and restate various parts of the Drawings and Specifications all of which shall form part of this Contract.

Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bid to be considered as non-responsive.

CHANGES TO SPECIFICATIONS (FROM BID NUMBER 016.20.B4-1)

REVISE

Line item in 2.01-C-1-a Sealer and finish coats

From: Sealer coats: Low-VOC [<350 g/L] oil-modified polyurethane wood sanding sealer, light in color, containing not less than 35% solids. Coliseum 100 produced by Buckeye (800.321.2583), no substitutions.

To: Sealer coats: Low-VOC [<275 g/L] oil-modified polyurethane wood sanding sealer, light in color, containing not less than 35% solids. Coliseum 100 produced by Buckeye (800.321.2583), no substitutions.

REVISE

Line item in 2.01-C-1-b Sealer and finish coats

From: Finish coats: Low-VOC [<350 g/L] oil-modified urethane wood floor coating, very light in color, containing not less than 50% solids. Coliseum 350 produced by Buckeye (800.321.2583), no substitutions.

To: Finish coats: Low-VOC [<100 g/L] oil-modified urethane wood floor coating, very light in color, containing not less than 50% solids. Coliseum 350 produced by Buckeye (800.321.2583), no substitutions.

NO CHANGES TO DRAWINGS (FROM BID NUMBER 016.20.B4-1)

END OF ADDENDUM NO. 9C-4

No Attachments