

**ADDENDUM NO. 3**

**November 28, 2022**

**RE: Controls Upgrade Cradlerock ES / Lake Elkhorn MS (HCPSS Bid #020.23.B3)**

**FROM: Purchasing Office  
Howard County Public Schools  
10910 Clarksville Pike  
Ellicott City, MD 21042  
(410) 313-6723  
(410) 313-6789 fax**

**TO: APPROVED PROSPECTIVE BIDDERS**

---

This addendum forms a part of the Contract Documents and modifies the Original Bidding Documents as noted below. Acknowledge receipt of this Addendum in the space provided on the Form of Proposal. Failure to do so may subject the Bidder to disqualification. This Addendum consists of one (s) pages.

**QUESTIONS:**

1. ACU-13 (ACH-15 on BAS), there is no mention of a motor replacement or VFD installation, is this correct? **Response: Yes, that is correct. There will be no motor replacement nor VFD installation for this unit.**
2. Will units on the final As-Built drawings match the current unit numbers on the BAS? **Response: Yes, the unit numbers in the contract drawings will be updated to match the current unit numbers in the BAS during the preparation of the as-built drawings.**
3. Will Pro-Press fittings be acceptable on piping changes? **Response: Yes, Pro-Press fittings are acceptable.**

**CHANGES TO THE DRAWINGS:**

1. None at this time.

**CHANGES TO THE SPECIFICATIONS:**

1. None at this time.

**END OF ADDENDUM NO. 3**