

ADDENDUM NO. 1

December 21, 2022

RE: Glenelg High School Heating Water System Upgrades (HCPSS Bid #054.23.B3)

**FROM: Purchasing Office
Howard County Public Schools
10910 Clarksville Pike
Ellicott City, MD 21042
(410) 313-6723
(410) 313-6789 fax**

TO: APPROVED PROSPECTIVE BIDDERS

This addendum forms a part of the Contract Documents and modifies the Original Bidding Documents as noted below. Acknowledge receipt of this Addendum in the space provided on the Form of Proposal. Failure to do so may subject the Bidder to disqualification. This Addendum consists of one (1) page.

QUESTIONS:

1. Are any of the roofs under warranty? **Response: Yes, the roof is under warranty. Refer to notes in Details 1 and 3 on Drawing M3.1.**
2. What type of roofs are on the building? **Response: 4-ply with a cap sheet.**
3. Does the school system have a preferred roofing company that should be considered for pricing? **Response: Refer to the notes in Details 1 and 3 on Drawing M3.1.**
4. Specifications 230529, 2.1.A.3, states that we are to design seismic hangers and supports for the piping. Please provide design category and coefficients. **Response: Seismic bracing and supports are not required for this project.**

CHANGES TO THE DRAWINGS:

1. None at this time.

CHANGES TO THE SPECIFICATIONS:

1. None at this time.

END OF ADDENDUM NO. 1