

ADDENDUM NO. 1

February 10, 2023

RE: Bid #051.23.B7, Elevator Modernization at Glenelg High School

**FROM: Purchasing Office
Howard County Public Schools
10910 Clarksville Pike
Ellicott City, MD 21042
(410) 313-6723
(410) 313-6789 fax**

TO: APPROVED PROSPECTIVE BIDDERS

This addendum forms a part of the Contract Documents and modifies the Original Bidding Documents as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Price Sheet/Form of Proposal. Failure to do so may subject the Bidder to disqualification. This Addendum consists of one (1) page.

The following clarification is provided to address the question regarding elevator communication which was raised during the pre-bid meeting:

Section 14 24 00

2.12.S. Communication Equipment

Add the following:

- d. Provide video requirements to meet A17.1 2019. Provide RATH SmartView Two-Way Elevator Visual Communication System or approved equal.**
- e. The Elevator Phone must be programmable to check the status of the incoming telephone line every 10 minutes up to every 23 hours. Upon failure to detect an active telephone line the elevator phone must provide a relay contact to an Annunciator Device (2100-ALARM) located at the designated landing in the vicinity of the "fire recall switch". Must function on analog, digital, cellular, or VoIP communication lines and allow for "communication failure" alarm.**
- f. Elevator Phone must allow for calls out on analog, digital, cellular, or IP communication lines.**
- g. Furnish and install CAT6 cabling as required from elevator machine room to owner's network switch located in media center MDF room and program elevator phone to operate on VoIP.**

END OF ADDENDUM